

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0065:120 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Faraday, 805 S.Maumee St., Tecumseh MI 49286
Contact: Steven A. Blohm (517) 423-2111 Fax (517) 423-2320

DESIGN: Models 852, 852A *, 854, 854A *, 15220, 15220A *, 15240, and 15240A *. Coded, noncoded or marchtime local; auxiliary, remote station protected premise, proprietary protected premise, central station protected premise; automatic, manual, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

15220/15240	Motherboard
15220A/15240A	Motherboard
15219	Zone Relay Module
15212	Remote Annunciator Module
15209	City Tie Module
15215	City Tie/Auxiliary Module
15217	Auxiliary Relay Module
15207	Supervisory Module
15213	Marchtime/Temporal Signal Module
15208	Troubleshooting Module
15206*	Communicator Interface Module

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or "FOS", model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control unit for use with separately listed compatible initiating and indicating devices.

*This control unit can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.

*Corrected 06-08-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager